

PENDELTON COUNTY NEEDS PROJECT – PENDELTON CO. MS/HS & NORTH FORK ES ROOF & HVAC



North Fork Elementary School has moss growing on roof due to standing water.



North Fork Elementary School's HVAC units are original and have outlived their life expectancy.



The existing HVAC units have outlived their life expectancy and are insufficient at Pendleton Co. Middle/High School.



There is water in light fixtures from where the roof leaks. Damaged ceiling tile is present throughout entire Pendleton MS/HS facility.