


School Building Authority of West Virginia
TYLER COUNTY - TYLER CONSOLIDATED MIDDLE/ HIGH - PHASE II HVAC & LIGHTING



Upgrades are planned for the auditorium and stage where inefficient ductwork and lighting are hanging from the ceiling.



The project proposes to upgrade equipment that is past its life-expectancy for the classrooms, auditorium, band, music, and an office suite.



Insulation is needed on the ducts in the gym to stop condensation from dripping and potentially damaging the wood floors.



This project will remove unused unit ventilators in classrooms on the second floor.