

School Building Authority of West Virginia
BERKELEY COUNTY– HVAC AND ROOF UPGRADES AT HEDGESVILLE HIGH SCHOOL



Mammoth Roof top unit showing ongoing replacement of compressors. Replacement parts are becoming obsolete.



Roof replacement is proposed over this portion of the facility. Ponding occurs as slopes fail.



High levels of carbon monoxide are present in occupied classrooms. Typically, 1100 PPM level and below is preferred.



Hedgesville High has one PreK class in rear of facility that will be served by the proposed new HVAC units.