

School Building Authority of West Virginia
CABELL COUNTY– HVAC AND RENOVATIONS AT SALT ROCK ES



The facility was funded by the SBA for a new HVAC system in 2013. That system has surpassed its 10-year life expectancy.



The current HVAC is susceptible to frequent power outages, which damage the compressors and controls.



Window AC units supplement the current HVAC system. These AC units will be switched out to heaters during the winter.



The facility has no fire sprinkler system. The Salt Rock Fire Department is ~500' from the school.