

School Building Authority of West Virginia
GILMER COUNTY – GILMER COUNTY MS/HS WATER TANK AND ROOF REPLACEMENT



The 500-gallon water tank, which serves the main building, is ~25 years old. Leaks have developed from the tank and lines.



The top of the water tank is completely rusted/corroded.



The EPDM roof is ~28 years old and has been leaking into classrooms, hallways and the science lab.



The metal roof (1988), which covers the clinic and new animal processing center, has been leaking since 2015.